



Board of Directors

Lisa M. Borba, AICP
President

Connstance Holdaway
Vice President

Ernesto A. Avila, P.E.

Bette Boatman

John A. Burgh

General Manager

Jerry Brown

June 8, 2018

All Proposers
Los Vaqueros Reservoir Inlet Structure
Gate 5 Underwater Rehabilitation
Project No. 116063

Subject: Addendum Number 1, Request for Proposal – Los Vaqueros Reservoir Inlet Structure Gate 5 Underwater Rehabilitation

Dear Proposers:

Notice is hereby given that the revisions shown in the attached Addendum Number 1 for the above project, dated *May 2018*, are hereby made a part of and incorporated into the Request for Proposal for Los Vaqueros Reservoir Inlet Structure Gate 5 Underwater Rehabilitation and will be used in the evaluation of proposals.

All proposers must acknowledge receipt of Addendum Number 1 in the space provided on Page 1 of Section 00300, **PROPOSAL FORM**, which forms part of the Proposal.

Please not the following: The proposal opening date and time of Friday, June 15th, 2018 @ 10:00 a.m. remains unchanged.

Sincerely,

A handwritten signature in blue ink that reads "Chris Hentz".

RM Rachel Murphy, P.E.
Director of Engineering

RM/PS:ck

Attachment

File No.: 116063

cc: Peter Stabb
Chris Hentz
Brian Jackson

ADDENDUM NO. 1

Project No. 116063

Description: Los Vaqueros Reservoir Inlet Structure Gate 5 Underwater Rehabilitation

Notice is hereby given that the Contract Documents for the above project shall be amended to include the following:

REVISIONS TO PROJECT SPECIFICATIONS

1-1 Section 00100, Instructions for Proposers

1-1.1 ADD the following paragraph to Section 00100-13.0, Interpretations:

"A copy of the remote operated vessel (ROV) video inspection of Gate 5 performed in December 2016 as referenced in Appendix 2 – ROV Inspection Report is available for download by submitting a request via email to Peter Stabb at pstabb@ccwater.com."

1-2 Section 01025, Measurement and Payment

1-2.1 ADD the following paragraph to Section 01025-2.0.A, Description of Bid Items – General, after the first paragraph:

"For purposes of the Pricing Schedule, the Contractor shall assume a one (1) day shift is comprised of multiple dives for a total bottom time of 180 minutes at Gate 5 for Bid Items 3,4,5,6,7,8,9,10,11, 12, A1, A4, A5, and A6. Extended work hours are allowed per Section 01010-3.0, Work Hours. In addition, Contractor shall provide description of actual work activities that may vary from those described in the narrative Work Plan section of the proposal as described in Section 00100-1.0, Instructions for Proposers – General."

1-2.2 REPLACE the last paragraph in Section 01025-2.0.B, Bid Item 1 Mobilization and Demobilization, with the following:

"Mobilization/Demobilization will include, but not limited to, the following items:

1. Site Specific Health and Safety Plan Submittal
2. Spill Containment Plan Submittal
3. Barge/Floating Work Platform Stability Analysis Submittal (if Hoist/Crane to be used)
4. Transportation and Assembly and Removal of Barges/Floating Work Platform
5. 3rd Party Crane Services (as needed) to Launch/Recover Equipment
6. Field Labor and Equipment to Support Mob/Demob
7. Spill Containment Materials"

1-2.3 ADD the following sentence to the end of the first paragraph in Section 01025-2.0.I, Bid Item 8 – Mobilize Into Sloping Intake and Apply Vibration to Gate Leaf:

"Impact hammer shall be Stanley BR45 Underwater Breaker/Driver, or equivalent."

1-2.4 REPLACE the first paragraph of Section 01025-2.0.L, Bid Item 11 – Replace Flexible Hydraulic Connectors with hard Line Fittings, to read as follows:

“Bid Item 11 includes, but is not limited to, replacing the flexible (hose) connectors at the hydraulic cylinder ports with hard line stainless steel high pressure tubing (piping), using mechanical fitting connections to match existing cylinder and tubing connections. All dimensions and fitting types shall be field verified prior to fabrication. The tubing for the other gates was modified during the Los Vaqueros Expansion Project and the specifications for that work are attached by Appendix 7.”

BIDDERS SHALL ACKNOWLEDGE THIS ADDENDUM ON SECTION 00300, BID



for Rachel Murphy
Director of Engineering