



Board of Directors

Lisa M. Borba, AICP
President

Connstance Holdaway
Vice President

Ernesto A. Avila, P.E.

Bette Boatman

John A. Burgh

General Manager

Jerry Brown

Addendum #2 dated April 29, 2019

Contra Costa Water District

Request for Proposal #2002

Questions and Answers for Generator Maintenance and Load Bank Testing

1. Can you please advise where we can find the pricing sheet or other required forms for this RFP?

Please visit the District's website at www.ccwater.com, under doing business with us and you will find all required information listed under RFP #2002.

2. What specific licenses are required to be provided in the Proposal? Scope is for testing and maintenance of generators. Do you want copies of the CA state driver's license?

All applicable license's to perform these services are required along with a valid driver's license.

3. I am looking to get a hold of the Sign-in sheet from the pre-bid meetings that were held on April 23rd and 24th for Generator Maintenance and Load Bank Testing?

Sign in sheets are posted to the District's website under RFP #2002.


4. The proposal request all SDS's to be provided with proposal. Can Contra Costa provide a list of oils, antifreeze and batteries used in the generators in order for us to provide the correct SDS's?

The coolant should be specified in the contract. If not it should be standard coolant per generator manufacturer specifications. As for the engine crankcase oil, It should be DELO 400 15-40 or equivalent. The batteries should per direct replacement of each engine driven generator. Typically lead acid batteries.

The RFP #2002 due date is hereby extended until 1:00 P.M. May 1, 2019.

This document is available online at www.ccwater.com, and is hereby made an official part of Request for Proposal #2002.

Thank you in advance for your cooperation.


Brian K. Jackson
Purchasing Officer
Contra Costa Water District

I acknowledge receipt of the foregoing Addendum #2.

Date: _____ Signature: _____